

# AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. PAGE 1 OF 2 PAGES

2. AMENDMENT/MODIFICATION NO.:  05	3. EFFECTIVE DATE  09/14/2006	4. PURCHASE REQUISITION NO.:	5A. SOLICITATION/CONTRACT/PROJECT TITLE  House Office Building Fire Protection System Inspection & Testing
			5B. PROJECT NO (If applicable)
6. ISSUED BY  <b>ARCHITECT OF THE CAPITOL</b> United States Capitol Washington, D.C. 20515		7. ADDRESS AMENDMENT/MODIFICATION TO Architect of the Capitol Procurement Division Ford House Office Building, Room H2-263 Attn: (Ryan Kirkwood) Second and "D" Streets, S.W. Washington, DC 20515	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		(X)	9A. AMENDMENT OF SOLICITATION NO. RFP060131
			9B. DATED (See Item 11) 08/16/2006
			10A. MODIFICATION OF CONTRACT/ORDER NO.
			10B. DATED (See Item 13)

## 11. THIS ITEM APPLIES ONLY TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of offers \_\_\_\_\_ is extended to DATE by TIME  
\_\_\_\_\_X\_\_\_\_\_ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning 2 copies of the amendment;

(b) By acknowledging receipt of this amendment in Block 12 of the AOC 33 or Block 19 of the AOC 1442 of the original solicitation package, giving amendment number and its date; or

(c) By separate letter which includes a reference to the solicitation and amendment numbers.

**FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.** If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter, provided each letter makes reference to the solicitation and this amendment, and is received prior to the opening/receipt hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

## 13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS AND MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

Check One			
	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT/ORDER NO. IN ITEM 10A.		
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b)(1)		
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:		
	D. OTHER (Specify type of modification and authority)		
E. IMPORTANT: Contractor _____ is not, _____ is required to sign this document and return it to the issuing office.			
14. DESCRIPTION OF AMENDMENT/MODIFICATION  The purpose of this amendment is to answer bidders questions. SEE CONTINUATION PAGE  Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.			
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME OF CONTRACTING OFFICER (Type or print)	
15B. OFFEROR/CONTRACTOR  _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA  By _____ (Signature of Contracting Officer)	16C. DATE SIGNED

This amendment is issued as follows: (The purpose of this amendment is to answer bidders questions).

**Question 1**

In working on the pricing for the Novec Gaseous Suppression Systems, it has come to my attention that they were just recently installed and BFPE has no information on them. Can you give me the tank sizes or can we visit the sites tomorrow (Thursday, September 14).

Answer:

NOVEC testing isn't related to tank size. However, the number of tanks is the same as the number of actuation solenoids listed in Section C.3.4 for each building.

**Question 2**

Also, is it fair to assume that the Novec, the Wet Chemical, and the Dry Chemical Systems are the same?

Answer:

Novec, Wet Chemical, and Dry Chemical Systems are not the same and have different requirements for testing and maintenance. Please read Section C of the RFQ for a description of testing and total number of systems.

Distribution:

Contract File